

## EC DECLARATION OF CONFORMITY

**B.D.Z. Energy System S.r.l.**  
**Via Perara 17/A - 36040 Orgiano (VI) - Italia**

Declares under their sole responsibility the conformity of the product: Tanks for solar hot water system:

Brand: **BARTA-THERMOKER KFT**

Model: **Puffer Kék-solar C/SS, C/1S, C/2S**

with the essential provisions of the Directive 97/23/CEE on Pressure Equipment and according to the application of the Standards below:

- DIN 4753 part 1 November 2011
- DIN 4753 part 2 January 1984
- DIN 4753 part 4 November 2011
- DIN 4753 part 9 September 1990
- UNI EN 10025 April 2005
- UNI EN 287-1 January 2012
- UNI EN ISO 9000

For this kinds of tanks, the following using parameters have to be respected :

- Maximum tank work temperature → T max = 95°C;
- Maximum heat exchangers work temperature → T max = 110°C;
- Maximum tank work pressure → 3 bar;
- Maximum heat exchangers work pressure → 10 bar.

Data: 18/01/2013

**Dott. Massimo Leopoldo Zanetti**  
B.D.Z. ENERGY SYSTEM S.r.l.  
General Manager

